



NOTES

1. CONTRACTOR TO INSTALL MUELLER 110 (CTS) 1" INLET - 7" HEIGHT H-1462-JN STRETCH METER BOX OR APPROVED EQUAL.
2. METER AND DUAL CHECK ASSEMBLY TO BE INSTALLED BY CITY.
3. CONTRACTOR SHALL INSTALL A MINIMUM OF 18" OF PIPING FROM ANY HARD SURFACE (I.E. CURB, SIDEWALK, ETC.) TO BOX INLET.
4. SEPARATE BACKFLOW PREVENTION DEVICE MAY BE REQUIRED BY BUILDING CODE.
5. FOR SERVICE PIPING CROSSING UNDER ROADWAY PAVEMENT (I.E. LONG SIDE SERVICE), PIPING IS TO BE PLACED WITH A MINIMUM OF 24" OF COVER FROM LIP OF GUTTER TO LIP OF GUTTER.

CITY OF ROCK HILL
 UTILITIES DEPARTMENT
 757 S. ANDERSON ROAD
 ROCK HILL, SC 29730



STANDARD DETAIL

SERVICE CONNECTION 1"

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	11.02
	SCALE: N.T.S.	