



NOTES

1. CONTRACTOR TO INSTALL 2" CDR A02-1730-18 METER BOX & COVER OR APPROVED EQUAL.
2. METER SETTER FOR 2" SERVICE SHALL BE MCDONALD 724-207WDQD33 OR APPROVED EQUAL.
3. MUELLER SYSTEMS MODEL MVR160 2-INCH TURBINE METER, 17-INCH LAYING LENGTH TO BE INSTALLED BY CITY.
4. CONTRACTOR TO INSTALL A MINIMUM OF 18" OF PIPING FROM ANY HARD SURFACE (I.E. CURB, SIDEWALK, ETC.) TO BOX INLET.
5. FOR NEW CONNECTION, 2" GATE VALVE IS TO BE LOCATED OUTSIDE PAVEMENT UNITS.
6. FOR SERVICE PIPING CROSSING UNDER ROADWAY PAVEMENT (I.E. LONG SIDE SERVICE), PIPING IS TO BE PLACED WITH A MINIMUM OF 24" COVER FROM LIP OF GUTTER TO LIP OF GUTTER.

CITY OF ROCK HILL
 UTILITIES DEPARTMENT
 757 S. ANDERSON ROAD
 ROCK HILL, SC 29730



STANDARD DETAIL		
SERVICE CONNECTION 2"		
REVISIONS:	DATE:	FILE NAME
	FEB. 2018	11.03
	SCALE:	
	N.T.S.	