



CUT-OFF VALVE

CUSTOMER SERVICE LINE

NOTE:

1. WATER PRESSURE REDUCING VALVE IS REQUIRED BY INTERNATIONAL BUILDING CODE 604.8 (ASSE 1003 WITH STRAINER) FOR ALL INSTALATIONS WHERE BUILDING FINISH FLOOR ELEVATION (FFE) IS AT OR BELOW ELEVATION 638 MSL.

PRV REQUIRED IF FFE IS 638' OR BELOW. ADJUST TO 80 PSI MAX.



WATER METER BOX

CUSTOMER'S RESPONSIBILITY

CITY OF ROCK HILL RESPONSIBILITY



STREET RIGHT OF WAY OR EASEMENT

BACK OF CURB OR EDGE OF PAVEMENT

SERVICE LINE



EXISTING STREET

EXISTING WATERMAIN LOCATED IN THE PUBLIC STREET R/W OR CITY UTILITY EASEMENT

CITY OF ROCK HILL
 UTILITIES DEPARTMENT
 757 S. ANDERSON ROAD
 ROCK HILL, SC 29730



STANDARD DETAIL		
SERVICE CONNECTION LOCATION		
REVISIONS:	DATE:	FILE NAME
	FEB. 2018	11.11
	SCALE:	
	N.T.S.	