



NOTES

1. BOTTOM SECTION TO BE CENTERED OVER NUT, NOT TO BEAR ON VALVE BODY.
2. PROVIDE CLEARANCE BETWEEN VALVE BOX/BRICK AND THE VALVE.
3. WHEN OPERATION NUT DEPTH EXCEEDS 4'-0" BELOW FINISHED GRADE, PROVIDE EXTENSION STEM WITH STD. 2" SQ. OPERATION NUT IN TOP SECTION OF VALVE BOX. EXTENSION STEM SHALL BE SIZED AS RECOMMENDED BY THE VALVE MANUFACTURER.
4. CONCRETE TO BE 3500 PSI.

CITY OF ROCK HILL
 UTILITIES DEPARTMENT
 757 S. ANDERSON ROAD
 ROCK HILL, SC 29730



STANDARD DETAIL

WATER VALVE BOX AND PAD

| | | |
|------------|-----------|-----------|
| REVISIONS: | DATE: | FILE NAME |
| | FEB. 2018 | 12.01 |
| | SCALE: | |
| | N.T.S. | |