



ELEVATION
NTS

NOTES

1. MECHANICAL JOINT SLEEVES REQUIRED FOR SIZE-ON-SIZE TAPS. ALL OTHER TAPS SHALL USE STAINLESS STEEL SLEEVES.
2. SEE CHART FOR APPROVED TAPPING SLEEVES.
3. INSTALLATION TO INCLUDE TEST PLUG.
4. BOLTS TO BE STAINLESS STEEL.
5. PRIOR TO TAPPING THE LINE, PROVIDE A HYDROSTATIC TEST ON THE SLEEVE PER CITY OF ROCK HILL SPECIFICATIONS.

STAINLESS STEEL
Ford – FAST Rockwell – 663 Smith Blair – 663 Power Seal – 3490AS Romac – 1980 SST

CITY OF ROCK HILL
UTILITIES DEPARTMENT
757 S. ANDERSON ROAD
ROCK HILL, SC 29730



STANDARD DETAIL		
WATER MAIN TAP – DIRECT		
REVISIONS:	DATE:	FILE NAME
	FEB. 2018	12.05
	SCALE:	
	N.T.S.	