



**NOTES**

1. CAN ONLY BE USED WITH PRIOR APPROVAL FROM CITY OF ROCK HILL UTILITY DEPT.
2. ALL JOINTS ARE TO BE RESTRAINED WITH STAINLESS STEEL TIE RODS AND/OR CONCRETE THRUST BLOCKING, AS CONDITIONS WARRANT.
3. SEE CHART FOR APPROVED TAPPING SLEEVES.
4. BOLTS TO BE STAINLESS STEEL.

**STAINLESS STEEL**

Ford – FAST  
 Rockwell – 663  
 Smith Blair – 663  
 Power Seal – 3490AS  
 Romac – 1980 SST

CITY OF ROCK HILL  
 UTILITIES DEPARTMENT  
 757 S. ANDERSON ROAD  
 ROCK HILL, SC 29730



<b>STANDARD DETAIL</b>		
<b>WATER MAIN TAP – BACKSIDE</b>		
REVISIONS:	DATE:	FILE NAME
	FEB. 2018	12.06
	SCALE:	
	N.T.S.	