



**NOTES**

1. MINIMUM R/W SHALL BE IN ACCORDANCE TO THE CITY OF ROCK HILL STANDARD SPECIFICATIONS.
2. IF CALCULATED TRENCH WIDTH IS LARGER THAN MINIMUM TRENCH WIDTH SET BY THE SPECIFICATIONS, THEN ROUND THE CALCULATED WIDTH UP TO THE NEAREST 5' AND USE THIS VALUE FOR THE RIGHT-OF-WAY WIDTH. (E.G. CALCULATED WIDTH IS 31', THEN USE A RIGHT-OF-WAY WIDTH OF 35')
3. ENGINEER OF RECORD SHALL VERIFY REQUIRED R/W WIDTH BASED ON DEPTH OF BURY OF PIPE.
4. NO STRUCTURES OR FOOTINGS FOR STRUCTURES SHALL BE PLACED WITHIN THE R/W.

**CERTIFICATION**

I CERTIFY THAT ALL EASEMENT WIDTHS SHOWN IN THIS PLAN CONFORM TO THE CITY OF ROCK HILL'S EASEMENT WIDTH DETERMINATION DETAIL.

ENGINEER

DATE

CITY OF ROCK HILL  
 UTILITIES DEPARTMENT  
 757 S. ANDERSON ROAD  
 ROCK HILL, SC 29730



**STANDARD DETAIL**

**EASEMENT WIDTH DETERMINATION  
 USING TRENCH SLOPE**

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	13.04
	SCALE:	
	N.T.S.	