



ELEVATION
NTS

DETAIL REFERENCE

1. 6" CONC. FOR 4'-0" DIA. MH
2. BRICK AND MORTAR FILL WITH GROUT FINISH
3. VARIABLE, MATCH CROWN WITH SEWER MAIN ON OUTLET PIPE
4. BRANCH SIZE SMALLER THAN SEWER, EXCEPT THAT MIN. SHALL BE 8" DIP
5. RUBBER BOOT
6. 1-90° BEND, DUCTILE IRON

NOTES

1. DROP MANHOLE FOR DROPS GREATER THAN 2'.
2. OUTSIDE DROP SHALL NOT ENTER MANHOLE IN CONE SECTION.

CITY OF ROCK HILL
UTILITIES DEPARTMENT
757 S. ANDERSON ROAD
ROCK HILL, SC 29730



STANDARD DETAIL

DROP MANHOLE

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	14.05
	SCALE:	
	N.T.S.	