



ELEVATION
NTS

NOTES

1. METER BASE AND DISCONNECT RATED FOR VOLTAGE AND AMPERAGE OF PUMP STATION CONTROL PANEL.
2. CONDUIT STUB UPS OUT OF GROUND WILL BE GALVANIZED RIGID TYPE, PVC CAN BE USED IN UNDER GROUND.
3. 1/4" ALUMINUM PLATE SHALL BE MOUNTED TO STAINLESS STRUT, ALL COMPONENTS SHALL BE MOUNTED TO ALUMINUM PLATE.
4. 3" GALVANIZED RIGID PIPE POSTS SHALL BE MINIMUM 3 FT. IN GROUND

CITY OF ROCK HILL
UTILITIES DEPARTMENT
757 S. ANDERSON ROAD
ROCK HILL, SC 29730



STANDARD DETAIL

PUMP STATION
CENTRAL CONTROL PANEL

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	16.04
	SCALE: N.T.S.	