



**NOTES**

1. CONFIGURATION MAY VARY DEPENDING ON PRIVATE PLUMBING CONTRACTOR.
2. ALL PRIVATE PLUMBING SHALL BE IN ACCORDANCE WITH SOUTH CAROLINA BUILDING CODE.
3. ALL VALVES SHALL HAVE VALVE BOXES PER VALVE BOX DETAIL.
4. THE PUMP BASIN COVER MUST BE A MINIMUM OF 2' ABOVE THE HIGH WATER MARK FOR LAKE WYLIE.
5. THE GRINDER PUMP MUST BE SECURED TO THE BASE TO PREVENT A FLOAT-AWAY CONDITION.

CITY OF ROCK HILL  
 UTILITIES DEPARTMENT  
 757 S. ANDERSON ROAD  
 ROCK HILL, SC 29730



**STANDARD DETAIL**

**LOW PRESSURE SEWER  
 INDIVIDUAL GRINDER PUMP SYSTEM**

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	18.01
	SCALE: N.T.S.	