



NOTES

1. DELETE CLEAN-OUTS UNLESS SHOWN ON SEWER PLAN SHEET OR REQUIRED AT HIGH POINTS FOR AIR RELEASE.
2. PIPE MATERIAL TO BE IPS PRESSURE-RATED PVC PIPE SDR 13.5, PC315.
3. 12 GAUGE SOLID COPPER TRACING WIRE TO PULL UP INTO BOX FOR LOCATING DEVICE CONNECTION.

CITY OF ROCK HILL
 UTILITIES DEPARTMENT
 757 S. ANDERSON ROAD
 ROCK HILL, SC 29730



STANDARD DETAIL

LOWER PRESSURE SEWER
 VALVES AND CLEANOUTS

REVISIONS:	DATE:	FILE NAME
	FEB. 2018	18.06
	SCALE: N.T.S.	