

Planning & Development Department

P.O. Box 11706, or 155 Johnston Street

Rock Hill, South Carolina 29731-1706

Phone: 803-329-5590 FAX: 803-329-7228

www.cityofrockhill.com



CONSTRUCTION DRIVES

Contractors must take necessary action to minimize the tracking of mud onto paved roadway from construction areas and the generation of dust. The contractor shall daily remove mud/soil from pavement, as may be required.

- A non-woven geotextile fabric should be installed prior to placing any stone.
- A culvert pipe should be placed across the entrance when needed to provide drainage.
- Minimum dimensions of the entrance should be 24 feet wide by 100 feet long
- The edges of the entrance should be tapered out towards the road to prevent tracking of mud at the edge of the entrance and so that long vehicles do not leave the stabilized area when turning onto or off of the paved roadway.
- The entrance should consist of a 2 to 3 inch D50 aggregate with a minimum thickness of 6 inches.
- Inspect entrance at least once every 7 calendar days and within 24 hours after each storm event of ½ inches of water or greater.
- Wash, replace or add stone whenever the entrance fails to perform effectively. Reshape the stone pad as needed for drainage and runoff control.

